

**CENELEC CERTIFICATION AGREEMENT**

CENELEC-ZERTIFIZIERUNGS-ABKOMMEN ● CCA ● ACCORD DE CERTIFICATION DU CENELEC

**Notification of Test Results (CCA-NTR)**

Certificate ref. no.:

**IK-1270**  
page 1 of 1

Product **Corrugated, pliable and insulating conduits**

Tested by request of **Tubifor srl  
Contrada Tempa Molino, IT-84032 Buonabitacolo**

Factory **Tubifor srl  
Contrada Tempa Molino, IT-84032 Buonabitacolo**

Ratings, characteristics **Classification: 3432 32  
Temperature: -15°C ... +90°C  
Diameters: 20, 25, 32, 40, 50**

Trade-mark **TUBIFOR**

Type/Model **ICTM**

Additional information **Resistance to compression: 1000N**

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standards

Safety: **EN 61386-1:08, EN 61386-22:04 + A11:10**

as shown in the test reports (reference no.)

Safety: **10-IK-0496.01**

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

The preliminary visit has been carried out by **Electrosuisse**.

This Notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11 th September 1973 and revised 29 th March 1983 with the addition of its Addenda 1,2,3 and 4. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

**Electrosuisse**  
**National Certification Body**

Martin Plüss  
Product Certification




**SCESp 035**  
**(EN 45011)**



**SIS 026**  
**(IEC/ISO 17020)**

Fehraltorf, 2011-03-01