

Certificate

System no. 5, type testing with assurance of conformity by production surveillance

CERTIFEL ZA5 **"Safety tested and supervised"**

Certificate ref. no. **IK-1269**

License ref. no. 141846



page 1 of 1

This certificate grants the right to use the mark of conformity

Product	Corrugated, pliable and insulating conduits
Licensee/License holder	Tubifor srl Contrada Tempa Molino, IT-84032 Buonabitacolo
Manufacturer	Tubifor srl Contrada Tempa Molino, IT-84032 Buonabitacolo
Manufactured at/Factory	Tubifor srl Contrada Tempa Molino, IT-84032 Buonabitacolo
Trade mark	TUBIFOR
Type/Model	ICTM
Ratings, characteristics	Classification: 3432 32 Temperature: -15°C ... +90°C Diameters: 20, 25, 32, 40, 50
Standards safety	EN 61386-1:08, EN 61386-22:04 + A11:10 IEC 61386-1(ed.2), IEC 61386-22(ed.1)
Standards EMC	---
Additional information	Resistance to compression: 1000N

The product was found to be in conformity with aforementioned standards, as shown in reports ref. no.: 10-IK-0496.01

Production surveillance according to European, CENELEC harmonised procedure.

This certificate has to be reissued every three years.

Electrosuisse
National Certification Body

Martin Plüss
Product Certification




SCESp 035
(EN 45011)



SIS 026
(IEC/ISO 17020)

Fehraltorf, 2011-03-01